



Nassau County Public Works Department

2290 State Road 200
Fernandina Beach, Florida 32034-3056

Jack J. D'Amato, Jr., PE
Director of Public Works

Gary R. Larson, CBO
Building Official

John H. Meier, PE
Civil Engineer

C. Dan Garlington, AICP
Planner

William Posten
Code Enforcement

MEMORANDUM

TO : John A. Crawford, Chairman
FROM : Jack J. D'Amato, Director of Public Works
DATE : July 7, 1997
SUBJECT : 14th Street Widening Project - Change Order for Milling

Background:

The following change order work has been recommended by Gee & Jenson, Inc.:

- Milling of existing pavement to a depth of 1 1/2" between Station 40 and 67
Total Cost.....\$ 20,000.00

Funding:

Funding is to come from the 14th Street contingency account. The amount of unallocated funds available is \$ 45,231.04.

Recommendation:

Staff recommends that the Board of County Commissioners approve the milling change order for the 14th Street Widening project.

APPROVED

DATE 7/14/97

*PWD
D'Amato*



GEE & JENSON
Engineers-Architects-Planners, Inc.

9452 Phillips Highway, Suite 4
Jacksonville, Florida 32256
Telephone (904) 292-9097
Fax (904) 292-4206

June 24, 1997

Jack D'Amato, P.E.
Director
Nassau County Public Works
2290 South 8th Street
Fernandina Beach, FL 32034-3056

Re: 14th Street Paving

Dear Mr. D'Amato:

As a result of our field review last week of the condition of the roadway base, we suggest that the existing pavement be milled to a depth of 1 1/2" between approximately Sta. 40 and Sta. 67. The cost of this work (done at night) would be about \$20,000. The cost of milling the entire roadway length would be about \$40,000.

Where necessary, leveling course material would be placed over the milled area prior to final paving.

If this is acceptable, we will prepare a Change Order for this work.

Very truly yours,

Harry W. Skahn, P.E.
Project Manager

HWS:sd
93255.60
cc: Henry Bradford

