

CS-13-31

RECEIVED

CONTRACT APPROVAL FORM CONTRACT MANAGEMENT

CONTRACTOR INFORMATION

2013 SEP 11 AM 9:45

Name: SPS, Szoke Power System

Address: PO Box 8897 Fleming Island, FL 32006  
City State Zip

Contractor's Administrator Name: Fred Szoke Title:

Tel#: 904-487-9515 Fax: Email: szokepower@hotmail.com

(Contract Management Use only)  
CONTRACT TRACKING NO.  
cm2022

CONTRACT INFORMATION

Contract Name: Generator Annual Maintenance and Service Agreement Contract Value: \$38,125.00

Brief Description: Provide Annual Maintenance and Service to County Owned Generators and provide service to any new generators the County may purchases that are not included on the list. (Various Locations).

Contract Dates: From: 10/1/13 to 9/30/16 Status: X New \_\_\_ Renew \_\_\_ Amend# \_\_\_ WA/Task Order

How Procured: \_\_\_ Sole Source \_\_\_ Single Source \_\_\_ ITB \_\_\_ RFP X RFQ<sup>u/c</sup> \_\_\_ Coop. \_\_\_ Other

If Processing an Amendment:

Contract #: Increase Amount of Existing Contract: No Increase

New Contract Dates: to TOTAL OR AMENDMENT AMOUNT:

13 SEP 20 AM 11:34  
RECEIVED  
COUNTY MANAGER'S  
OFFICE

APPROVALS PURSUANT TO NASSAU COUNTY PURCHASING POLICY, SECTION 6

- 1. [Signature] 9/3/13  
Department Head Signature Date  
Various Locations  
Funding Source/Acct #
- 2. [Signature]  
Contract Management Date  
See attached list for the funding accounts,  
agreement to include any additional generators  
purchased by Nassau County.
- 3. [Signature] 9-18-13  
Office of Management & Budget Date
- 4. [Signature] 9/20/13  
County Attorney (approved as to form only) Date

Comments:

COUNTY MANAGER - FINAL SIGNATURE APPROVAL

[Signature] 9/19/13  
Ted Selby Date

13 SEP 13 AM 10:53  
RECEIVED  
COUNTY MANAGER'S  
OFFICE

RETURN ORIGINAL(S) TO CONTRACT MANAGEMENT FOR DISTRIBUTION AS FOLLOWS:

- Original: Clerk's Services; Contractor (original or certified copy)
- Copy: Department  
Office of Management & Budget  
Contract Management  
Clerk Finance

2013 SEP 23 PM 12:53

CONTRACT MANAGEMENT

RECEIVED

**SPS, Szoke Power System**

**PO Box 8897  
Fleming Island, Fl. 32006  
Phone (904) 487-9515  
Email: szokepower@hotmail.com**

Date: August 13, 2013


**Nassau County Board of County Commissioners  
Generator Annual Maintenance and Service Agreement**

SPS, Szoke Power System is a fully insured generator maintenance company. Our services include providing the Annual Maintenance and Service and repairs, for the county owned generators. SPS Szoke Power System maintains a drug- free work place.


Board of County Commissioners of Nassau County, hereinafter called the "Owner" and SPS, Szoke Power System, hereinafter called the "Contractor," in consideration of the mutual covenants herein contained and of other good and valuable consideration, the receipt of which is hereby acknowledged, hereby agrees as follows:

1. **Duration of Contract.** The contractor shall perform its services under this contract, as set forth on the Scope of Work. All prices are guaranteed for three (3) years effective October 1, 2013- through September 30, 2016. This contract may be cancelled by either party upon thirty (30) days written notice.
2. **Services.** The Contractor shall perform the services as listed in the attached Scope of Work.
3. **Payment.** The Owner shall pay to the Contractor for services under this Contract as per the Florida Statutes 218.73 & 218.74. (Terms Net 45 Days) Payment shall be remitted to: SPS, Szoke Power System, PO Box 8897, Fleming Island, FL. 32006

The Parties have signed and agreed to this contract as of the date set forth below.

  
\_\_\_\_\_  
SPS, Szoke Power System  
Fred Szoke, President

September 5, 2013  
Date

  
\_\_\_\_\_  
Representative  
Nassau County Board of County Commissioners

9/19/13  
Date

**NASSAU COUNTY**  
**FACILITIES MAINTENANCE DEPARTMENT**

Office Mailing Address: 45195 Musselwhite Road - Callahan, FL 32011

Nassau County BOCC Mailing Address:  
76347 Veterans Way, Suite 4000 –Yulee, FL 32097  
Email: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)

Telephone: (904) 548-4688  
Alternate: (904) 879-3751  
Fax: (904) 548-4687

**SCOPE of WORK**

(All requests for quotations must be accompanied by this Scope of Work)

**Nassau County Board of County Commissioners**  
**Generator Annual Maintenance and Service Agreement**

Nassau County is requesting quotations for the Annual Maintenance and Service required for each County Owned Generator, as well as any new generators purchased during agreement period. (See attached list indicating the location and Generator information.)

Provide rates for the following: Annual Maintenance and Service as required per Generator:

- 3 Quarterly Minor Services
- 1 Major Service
- 1 Load Bank Test
- List materials with applicable charges for each Generator as listed.

Provide rates for the following services or charges:

- Regular Hourly rate.
- Overtime Hourly rate.
- Any additional mileage charge.
- Truck Charges
- Environmental Charges (that would be applicable for any work, scheduled or unscheduled).
- Any charge not listed please provide detailed information.

\*Please Note:

- Prior to ***any work***, scheduled or unscheduled, proper authorization must be obtained. A PO number will be issued for Annual Maintenance, for any additional repairs a control number must be obtained by contacting the office or through the technician reporting service needs.
- Funding Accounts Numbers have been provided to identify each generator by the department. Please indicate this on all and any invoices to expedite billing processing.
- As generators are being replaced with new units, we will be placing the existing generators at other locations. New units will be under warrantee for the first year. (as noted on attached spreadsheet).
- Please provide costs for each Annual Maintenance Service for the following period.
  - Oct1, 2013 - Sept 30, 2014= FY 13/14
  - Oct1, 2014 - Sept 30, 2015= FY 14/15
  - Oct1, 2015 - Sept 30, 2016= FY 15/16

Please respond with pricing to our office by August 14, 2013, should you want to be considered for the Annual Maintenance and Service Agreement, if not please respond with a "No Quote".

All prices must be guaranteed for three (3) years effective October 1, 2013- through September 30, 2016. Any questions you may have please contact Don Castle 904-753-1046, you may also email our Director-Bob Knott at: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)



**Suzie Fontes**

---

**From:** Jimmy Jacobs <JJacobs@fdda.com>  
**Sent:** Tuesday, August 13, 2013 4:04 PM  
**To:** Suzie Fontes  
**Subject:** RE: 2010 generator maintenance RFQ - Bid Tabulation

Thanks Suzie.

*Jimmy Jacobs*  
Florida Detroit Diesel-Allison, Inc.  
Generator/Fire Pump  
Field Service Sales Rep.  
407-888-1700 Office  
866-902-4064 Fax  
407-948-7402 Mobile



---

**From:** Suzie Fontes [mailto:sfontes@nassaucountyfl.com]  
**Sent:** Tuesday, August 13, 2013 3:55 PM  
**To:** Jimmy Jacobs  
**Subject:** RE: 2010 generator maintenance RFQ - Bid Tabulation

Please forgive me for the delay.

Here is the Quotes Received from 6/1/11

Szokes Power Systems Annual	\$	25,080.00
Florida Detroit Diesel	\$	25,995.00
Ring Power	\$	26,401.00
N. Fl. Power Systems	\$	28,389.00

*Emailed this info to all vendors solicited*

---

**From:** Jimmy Jacobs [mailto:JJacobs@fdda.com]  
**Sent:** Monday, August 12, 2013 10:10 AM  
**To:** Suzie Fontes  
**Subject:** Re: 2010 generator maintenance RFQ - Bid Tabulation

Thank you.

Sent from my iPhone

On Aug 12, 2013, at 10:09 AM, "Suzie Fontes" <sfontes@nassaucountyfl.com> wrote:

Great, I have reached out to another department to see if we can get a Bid Tabulation for you.

NASSAU COUNTY  
FACILITIES MAINTENANCE DEPARTMENT

Office Mailing Address: 45195 Musselwhite Road - Callahan, FL 32011

Nassau County BOCC Mailing Address:  
76347 Veterans Way, Suite 4000 - Yulee, FL 32097  
Email: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)

Telephone: (904) 548-4688  
Alternate: (904) 879-3751  
Fax: (904) 548-4687

**SCOPE of WORK**

(All requests for quotations must be accompanied by this Scope of Work)

**Nassau County Board of County Commissioners**  
**Generator Annual Maintenance and Service Agreement**

Nassau County is requesting quotations for the Annual Maintenance and Service required for each County Owned Generator, as well as any new generators purchased during agreement period. (See attached list indicating the location and Generator information.)

Provide rates for the following: Annual Maintenance and Service as required per Generator:

- 3 Quarterly Minor Services
- 1 Major Service
- 1 Load Bank Test
- List materials with applicable charges for each Generator as listed.

Provide rates for the following services or charges:

- Regular Hourly rate.
- Overtime Hourly rate.
- Any additional mileage charge.
- Truck Charges
- Environmental Charges (that would be applicable for any work, scheduled or unscheduled).
- Any charge not listed please provide detailed information.

\*Please Note:

- Prior to any work, scheduled or unscheduled, proper authorization must be obtained. A PO number will be issued for Annual Maintenance, for any additional repairs a control number must be obtained by contacting the office or through the technician reporting service needs.
- Funding Accounts Numbers have been provided to identify each generator by the department. Please indicate this on all and any invoices to expedite billing processing.
- As generators are being replaced with new units, we will be placing the existing generators at other locations. New units will be under warranty for the first year. (as noted on attached spreadsheet).
- Please provide costs for each Annual Maintenance Service for the following period.
  - Oct1, 2013 - Sept 30, 2014= FY 13/14
  - Oct1, 2014 - Sept 30, 2015= FY 14/15
  - Oct1, 2015 - Sept 30, 2016= FY 15/16

Please respond with pricing to our office by August 14, 2013, should you want to be considered for the Annual Maintenance and Service Agreement, if not please respond with a "No Quote".

All prices must be guaranteed for three (3) years effective October 1, 2013- through September 30, 2016. Any questions you may have please contact Don Castle 904-753-1046, you may also email our Director-Bob Knott at: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)

**Suzie Fontes**

---

**From:** Suzie Fontes  
**Sent:** Friday, August 09, 2013 3:48 PM  
**To:** mmcgauley@fdda.com  
**Subject:** FW: Nassau County Generator- Request for Quote  
**Attachments:** Florida Detroit Disel Gen Quote.pdf; Revised 8.9.13 All Generator Locations.xls

Please see the attached Amendment #1 to the Generator Spreadsheet sent out on August 2, 2013. I also attached the Original Request - Scope of Work. We are extending the due date to August 19, 2013 due to the revisions.

Thank you,

---

**From:** Suzie Fontes  
**Sent:** Friday, August 02, 2013 10:25 AM  
**To:** 'mmcgauley@fdda.com'  
**Subject:** FW: Nassau County Generator- Request for Quote

---

**From:** Suzie Fontes  
**Sent:** Friday, August 02, 2013 10:07 AM  
**To:** 'mmcgauley@fdea.com'  
**Subject:** Nassau County Generator- Request for Quote

Emailed on Behalf of Don Castle:

Please see all attachments.

Suzie Fontes - Office Manager  
Nassau County Facilities Maintenance/Parks & Recreation Dept.  
45195 Musselwhite Road, Callahan, FL 32011  
Office 904-548-4688 ext 6303 Fax: 904-548-4687

Amendment #1  
 Sent to All 8/9/13  
 Extending Due Date  
 to 8-19-13

These Columns are County Reference.		NASSAU COUNTY GE			3 Year Service Agreement Oct 1 2013-9 30 2016				
DEPT	Nassau County Funding Account (For Budget Purposes)	LOCATION	VOLTS	PHASE	1st Minor Quarterly PM	2nd Minor Quarterly PM	3rd Minor Quarterly PM	12 Hour Load Test	One Annual Major PM
NAU	546000 71500536-546000	Nassau Amelia Utilities	480	3	Y	Y	Y	NO	Y
NAU	71500536-546000	Nassau Amelia Utilities	480	3	Y	Y	Y	NO	Y
NAU	71500536-546000	Nassau Amelia Utilities Plant	230/480	1-3 Phase	Y	Y	Y	NO	Y
NAU	71500536-546000	Nassau Amelia Utilities Plant	480	3	Y	Y	Y	NO	Y
NAU	71500536-546000	Nassau Amelia Utilities - Lift Station 16	208	3	Y	Y	Y	NO	Y
JPGC	01073519 01188519-546036	James Page Governmental Complex-Onan	120/240	THREE	Y	Y	Y	Y	Y
JPGC	01188519-546036	James Page Governmental Complex-Detroit Diesel	480	THREE	Y	Y	Y	Y	Y
Judicial Annex	01074712 01189712-546000	Judicial Annex-Courthouse	480	THREE	Y	Y	Y	Y	Y
Judicial Annex-Rec.	01189712-546000	Judicial Annex Records Management Building	480	THREE	Y	Y	Y	Y	Y
Other Co. Bldgs	01073519 011893519-546036	Sheriff Admin- 911 Dispatch	480	THREE	Y	Y	Y	Y	Y
Other Co. Bldgs	01093519-546036	Repeater Tower - West Side at Landfill	240	SINGLE	Y	Y	Y	Y	Y
Other Co. Bldgs	01093519-546036	Hilliard Health Clinic (Health Dept Reimburses Court)	240	THREE	Y	Y	Y	No	Y
	01072523-546036	Detention Center, Jail		THREE	Y	Y	Y	Y	Y
Fire Rescue	01261526-546000	Fire Rescue #30 (Relocating a Tower Site 50 KW to th	240	SINGLE	Y	Y	Y	No	Y
Fire Rescue	01261526-546000	Fire Rescue #40	240	SINGLE	Y	Y	Y	No	Y
Fire Rescue	01261526-546000	Vol Station #7	240	SINGLE					Y
Fire Rescue	01261526-546000	Vol Station #3	240	SINGLE					Y
Fire Rescue	01261526-546000	Fire Rescue #70 (Relocating a Tower Site 50 KW to th	240	SINGLE	Y	Y	Y	No	Y
Fire Rescue	01261526-546000	Fire Rescue Head Quarters & Fire Rescue 20 (NEW)	240	SINGLE	Y	Y	Y	No	Y
BOCC Radio	01252525-546000-MCOMM	Hilliard Tower Site (Current units will be placed throu	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	Callahan Tower Site (Current units will be placed thre	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	Bryceville Tower Site (Current units will be placed thru	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	Yulee Tower Site (Current units will be placed throug	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	Fernandina Beach Tower Site (Current units will be pl	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	Yulee Master Site (Current units will be placed throug	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower	240	SINGLE	Y	Y	Y	Y	Y
BOCC Radio	01252525-546000-MCOMM	New Trailer Mount Generators will be purchased 13/14	240	SINGLE	Y	Y	Y	Y	Y
Solid Waste	70362534-546000	Landfill East Side Pumping Station	240	SINGLE	Y	Y	Y	No	Y
Solid Waste	70362534-546000	Landfill West Side Pumping Station	240	Three	Y	Y	Y	No	Y
Solid Waste	70362534-546000	Landfill Leachate Pumping Station	240	Three	Y	Y	Y	No	Y
Solid Waste	70362534-546000	Landfill Flare System (New Unit installed on 4/29/13)	480	Three	Y	Y	Y	No	Y
Solid Waste	70369534-546000	Landfill Convenience Center	120/240	Three	Y	Y	Y	No	Y
Animal Control	011893519-546036	Animal Control and Care Service	120/240	SINGLE	Y	Y	Y	No	Y
Emergency Services	01093519-546036	Emergency Operations Center	120/208	Three	Y	Y	Y	Y	Y
Hilliard R&B	03404541-546000	Hilliard Road & Bridge-Office	240	SINGLE	No	No	No	No	Y
Bailey Road	03404541-546000	Hilliard Road & Bridge - Shop	240	SINGLE	No	No	No	No	Y
Road and Bridge	03404541-546000	Bailey Road & Bridge	240	SINGLE	No	No	No	No	Y

29/8/12





Nassau County Board of County Commissioners  
Request for Quotation Form

Requesting Department: Facilities Maintenance Date: 8/2/13

Department Address: 45195 Musselwhite Road, Callahan, FL 32011

Contact: Don Castle (Maintenance Tech.) 904-753-1046  
or Bob Knott (Director) 904-548-4688

Contact email: Bob Knott- Director: bknott@nassaucountyfl.com

Department Phone: (904) 548-4688 or (904) 548-4689

Department Fax: (904) 548-4687

Product(s)/Service(s) to be purchased (list all specifications and requirements):

See attached Scope of Work for Nassau County Board of County Commissioners-Generator Annual Maintenance and Service Agreement (See attached documents).

**Please note:**

**This document must be completed and sent back with the attached Scope of Work with your quotation.**

➤ If additional/alternate scope of service or product is recommended, please provide as a separate attachment: Additional Attachment Yes  No

\*All payments for products /services are as per Florida Statutes 218.73 & 218.74 (Terms net 45 days). \*

Please submit written response by: August 14, 2013 *extended date 8/19/13*  
(Date)

Faxed / Scanned/Emailed to Vendor on 8/2/13 to the attention of FRED

To be completed by vendor:

Vendor Name: Szokes Power Systems

Address: 2153 Blue Heron Cove Drive

Fleming Island, FL 32003

Phone: 904-487-9515 Fax: N/A

Contact: Fred Szoke

Email: szokepower@hotmail.com

Attached is a written quote from our company, which is valid for 60 days.

  
Signature

8-13-2013  
Date

Comments: \_\_\_\_\_

**NASSAU COUNTY  
FACILITIES MAINTENANCE DEPARTMENT**

Office Mailing Address: 45195 Musselwhite Road - Callahan, FL 32011

Nassau County BOCC Mailing Address:  
76347 Veterans Way, Suite 4000 - Yulee, FL 32097  
Email: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)

Telephone: (904) 548-4688  
Alternate: (904) 879-3751  
Fax: (904) 548-4687

**SCOPE of WORK**

(All requests for quotations must be accompanied by this Scope of Work)

**Nassau County Board of County Commissioners  
Generator Annual Maintenance and Service Agreement**

Nassau County is requesting quotations for the Annual Maintenance and Service required for each County Owned Generator, as well as any new generators purchased during agreement period. (See attached list indicating the location and Generator information.)

Provide rates for the following: Annual Maintenance and Service as required per Generator:

- 3 Quarterly Minor Services
- 1 Major Service
- 1 Load Bank Test
- List materials with applicable charges for each Generator as listed.

Provide rates for the following services or charges:

- Regular Hourly rate.
- Overtime Hourly rate.
- Any additional mileage charge.
- Truck Charges
- Environmental Charges (that would be applicable for any work, scheduled or unscheduled).
- Any charge not listed please provide detailed information.

\*Please Note:

- Prior to any work, scheduled or unscheduled, proper authorization must be obtained. A PO number will be issued for Annual Maintenance, for any additional repairs a control number must be obtained by contacting the office or through the technician reporting service needs.
- Funding Accounts Numbers have been provided to identify each generator by the department. Please indicate this on all and any invoices to expedite billing processing.
- As generators are being replaced with new units, we will be placing the existing generators at other locations. New units will be under warrantee for the first year. (as noted on attached spreadsheet).
- Please provide costs for each Annual Maintenance Service for the following period.
  - Oct1, 2013 - Sept 30, 2014= FY 13/14
  - Oct1, 2014 - Sept 30, 2015= FY 14/15
  - Oct1, 2015 - Sept 30, 2016= FY 15/16

Please respond with pricing to our office by August 14, 2013, should you want to be considered for the Annual Maintenance and Service Agreement, if not please respond with a "No Quote".

All prices must be guaranteed for three (3) years effective October 1, 2013- through September 30, 2016. Any questions you may have please contact Don Castle 904-753-1046, you may also email our Director-Bob Knott at: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)

## Rate Sheet

SPS, Szoke Power Systems Inc, is pleased to present these rates to you.

SPS works five days per week, Monday through Friday

We charge:

\$78 per hour regular time. 8am to 4:30 pm.

\$117 per hour for overtime and Saturday work

\$156 per hour for Sundays and holidays

Time starts when vehicle is started.

Travel is \$1.00 per mile, from Fleming Island, FL. (between Orange Park and Green Cove Springs FL)

SPS is on call 24/7 and will always have my phone nearby.

SPS has new model year, dependable trucks, fully loaded with tools and service manuals.

SPS uses GPS navigation to find any site you give, and I keep those sites mapped.

SPS is fully insured.

Thank you for considering SPS to provide your service needs.

Fred Szoke

## Suzie Fontes

---

**From:** Fred Szoke <szokepower@hotmail.com>  
**Sent:** Thursday, August 22, 2013 11:30 AM  
**To:** Suzie Fontes  
**Subject:** Re: Mileage charges

Yes

Whichever point to benefit customer

Sent from my iPhone Fred Szoke Power Systems Inc

On Aug 22, 2013, at 10:54 AM, "Suzie Fontes" <[sfontes@nassaucountyfl.com](mailto:sfontes@nassaucountyfl.com)> wrote:

> Confirming the cost is \$1.00 per mile from any point that you are at.

>

> -----Original Message-----

> From: Fred Szoke [mailto:[szokepower@hotmail.com](mailto:szokepower@hotmail.com)]

> Sent: Thursday, August 22, 2013 10:41 AM

> To: Suzie Fontes

> Cc: Fred Szoke

> Subject: Mileage charges

>

> Service calls will generate a mileage charge from the point of contact

> if I am at office mileage will be from Fleming Island Florida to the job

> site

>

> If I am already in Jacksonville or in Nassau County it'll be from that

> point of contact whatever is closer for customer benefit

>

> If I am in Orlando working it would be from the my Office

>

> These charges are to offset fuel Maintenance costs

> Please let me know if you need anything else thank you

>

> Sent from my iPhone Fred Szoke Power Systems Inc

These Columns are County Reference.

NASSAU COUNTY GENERATORS

Szokes

Changes are highlighted in BLUE

DEPT.	Nassau County Funding Account (For Budget Purposes).	LOCATION	ADDRESS	PRIMARY USE	Service Requirements.	3 Minor Quarterly PM	2 Hour Load Test	One Major PM	BRAND	KW	VOLTS	PHASE
NAU	71500536-546000	Nassau Amelia Utilities	5390 First Coast Highway, FB FL 32034	Waste Water Plant	1 Annual Major Service Inspection			Y	CAT	400KVA	480	3
NAU	71500536-546000	Nassau Amelia Utilities	Omni/Plantation 6027 Villa Partial 3	Repump WTP	1 Annual Major Service Inspection			Y	CAT	565KW	480	3
NAU	71500536-546000	Nassau Amelia Utilities Plant	5390 First Coast Highway, FB FL 32034	Trailer Mount Generator	1 Annual Major Service Inspection			Y	Armstrong Power	140KVA	230/480	1-3 Phase
NAU	71500536-546000	Nassau Amelia Utilities Plant	5390 First Coast Highway, FB FL 32034	Water Treatment Plant	1 Annual Major Service Inspection			Y	CAT D343	312 KVA	480	3
NAU	71500536-546000	Nassau Amelia Utilities - Lift Station 16	6 Amelia Village Circle, FB FL 32034	Lift Station 16	1 Annual Major Service Inspection			Y	ONAN	85 KW	208	3
JPGC	01188519-546036	James Page Governmental Complex-Onan	96135 Nassau Place, Yulee	COMM. BOARD RM	One major, three minors, full 2 hour load bank test.	Y	Y	Y	ONAN	60	120/240	THREE
JPGC	01188519-546036	James Page Governmental Complex-Detroit Diesel	96135 Nassau Place, Yulee	Prop Appr. SOE & Tax Collector	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Detroit Diesel	125	480	THREE
Judicial Annex	01189712-534000	Judicial Annex-Courthouse	76435 Veteran's Way, Yulee	JUDICIAL COURTHOUSE	One major, three minors, full 2 hour load bank test.	Y	Y	Y	CUMMINS	300	480	THREE
Judicial Annex-Rec.	01189712-534000	Judicial Annex Records Management Building	76435 Veteran's Way, Yulee	RECORDS MAN. BLDG.	One major, three minors, full 2 hour load bank test.	Y	Y	Y	CATERPIL	75	480	THREE
Other Co. Bldgs	01193519-546036	Sheriff Admin- 911 Dispatch	50 Bobby Moore Circle, Yulee	911 DISPATCH	One major, three minors, full 2 hour load bank test.	Y	Y	Y	GENERAC	100	480	THREE
Other Co. Bldgs	01193519-546036	Repeater Tower - West Side at Landfill	46351 Landfill Rd, Callahan Florida.	REPEATER TOWER WEST SIDE	One major, three minors, full 2 hour load bank test.	Y	Y	Y	GENERAC	15	240	SINGLE
Other Co. Bldgs	01193519-546036	Hilliard Health Clinic (Health Dept Reimburses County)	221 Pecan St., Hilliard, Fl. 32046	HEALTH DEPT.	One major, three minors	Y	N	Y	KOHLER	15	240	THREE
	01072523-546036	Detention Center, Jail	76212 Nicholas Catinha Rd. Yulee	DETENTION CENTER	One major, three minors, full 2 hour load bank test.	Y	Y	Y	TAYLOR	300		THREE
Fire Rescue	01261526-546000	Fire Rescue #30 (Relocating a Tower Site 50 KW to this location Oct 2013)	86026 Pages Dairy Rd., Yulee	FR #30	One major, three minors.	Y	N	Y	GENERAC	50	240	SINGLE
Fire Rescue	01261526-546000	Fire Rescue #40	Pea Farm Rd. Hilliard	FR #40 & WELL	One major, three minors.	Y	N	Y	GENERAC	50	240	SINGLE
Fire Rescue	01261526-546000	Vol Station #7	1426 Nassauville Rd., Fernandina Beh.	MOBILE	1 Annual Major Service Inspection	N	N	Y	KUBOTA	6	240	SINGLE
Fire Rescue	01261526-546000	Vol Station #3	Goodbread Drive Yulee, FL 32097	MOBILE UNIT	1 Annual Major Service Inspection	N	N	Y	KUBOTA	6	240	SINGLE
Fire Rescue	01261526-546000	Fire Rescue #70 (Relocating a Tower Site 50 KW to this location Oct 2013)	4061 Pine Grove Rd.(O'Neil), FB, FL 32034		One major, three minors, full 2 hour load bank test.	Y	N	Y	Generac	50	240	SINGLE
Fire Rescue	01261526-546000	Fire Rescue Head Quarters & Fire Rescue 20 (NEW)	96160 Nassau Place, Yulee, FL 32097	Trailer Mount-	One major, three minors, full 2 hour load bank test.	Y	N	Y	Tradewind	56	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	Hilliard Tower Site (Current units will be placed throught the Co.)	371105 Oxford St, Hilliard	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	35	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	Callahan Tower Site (Current units will be placed throught the Co.)	46351 Landfill Rd	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	50	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	Bryceville Tower Site (Current units will be placed throught the Co.)	11701 Old North Trail	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	35	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	Yulee Tower Site (Current units will be placed throught the Co.)	462684 SR 200	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	50	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	Fernandina Beach Tower Site (Current units will be placed throught the Co.)	1559 S 14th St	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	25	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	Yulee Master Site (Current units will be placed throught the Co.)	76001 Bobby Moore Circle	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	50	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	35	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	50	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	35	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	50	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	25	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	50	240	SINGLE
BOCC Radio	1252525-546000-MCOMM	New Trailer Mount Generators will be purchased 13/14		Trailer Mount	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	50	240	SINGLE
Solid Waste	70362534-546000	Landfill East Side Pumping Station	46026 Landfill Road, Callahan 32011	Pumping stations	One major, three minors	Y	N	Y	Caterpillar	23.3	240	SINGLE
Solid Waste	70362534-546000	Landfill West Side Pumping Station	46026 Landfill Road, Callahan 32011	Pumping stations	One major, three minors	Y	N	Y	Hollingsworth	30	240	Three
Solid Waste	70362534-546000	Landfill Leachate Pumping Station	46026 Landfill Road, Callahan 32011	Leachate Tanks Pumping	One major, three minors	Y	N	Y	Onan	40	240	Three
Solid Waste	70362534-546000	Landfill Flare System (New Unit installed on 4/29/13)	46026 Landfill Road, Callahan 32011	Flare System	One major, three minors	Y	N	Y	Tradewind	125	480	Three
Solid Waste	70369534-546000	Landfill Convenience Center	46026 Landfill Road, Callahan 32011	Convenience Center	One major, three minors	Y	N	Y	Caterpillar	60	120/240	Three
Animal Control	01193519-546036	Animal Control and Care Service	86078 License Road Yulee 32097	Building and Kennels	One major, three minors	Y	N	Y	Maspower	35.2	120/240	SINGLE
Emergency Services	01253525-546036	Emergency Operations Center	77150 Citizen's Circle Yulee 32097	Building	One major, three minors, full 2 hour load bank test.	Y	Y	Y	GENERAC	150	120/208	Three
Hilliard R&B	03404541-546000	Hilliard Road & Bridge-Office	37356 Pea Farm Rd. Hilliard, Fl.	Hilliard Yard Main Office	1 Annual Major Service Inspection	N	N	Y	GENERAC	30	240	SINGLE
Bailey Road	03404541-546000	Hilliard Road & Bridge - Shop	37356 Pea Farm Rd Hilliard, Fl.	Hilliard Yard Maintenance Shop	1 Annual Major Service Inspection	N	N	Y	GENERAC	30	240	SINGLE
Road and Bridge	03404541-546000	Bailey Road & Bridge	3163 Bailey Rd. Fernandina Beh. Fl.	Bailey Yard	1 Annual Major Service Inspection	N	N	Y	GENERAC	20	240	SINGLE







Nassau County Board of County Commissioners  
Request for Quotation Form

Requesting Department: Facilities Maintenance Date: 8/2/13

Department Address: 45195 Musselwhite Road, Callahan, FL 32011

Contact: Don Castle (Maintenance Tech.) 904-753-1046  
or Bob Knott (Director) 904-548-4688

Contact email: Bob Knott-Director: bknott@nassaucountyfl.com  
Department Phone: (904) 548-4688 or (904) 548-4689  
Department Fax: (904) 548-4687

Product(s)/Service(s) to be purchased (list all specifications and requirements):

See attached Scope of Work for Nassau County Board of County Commissioners-Generator Annual Maintenance and Service Agreement (See attached documents).

**Please note:**

**This document must be completed and sent back with the attached Scope of Work with your quotation.**

➤ If additional/alternate scope of service or product is recommended, please provide as a separate attachment: Additional Attachment Yes  No

\*All payments for products /services are as per Florida Statutes 218.73 & 218.74 (Terms net 45 days). \*


Please submit written response by: August 14, 2013 *extended 8/19/13 SK*  
(Date)

Faxed / Scanned/Emailed to Vendor on 8/2/13 to the attention of ~~JL Power~~  
JL POWER SYSTEMS, INC.

To be completed by vendor:

Vendor Name: ~~JL Power Systems~~ JL POWER SYSTEMS, INC.  
Address: 3625 ASBURY TRACE DRIVE  
GREEN COVE SPRINGS, FL 32043  
Phone: 904-282-8909 Fax: 904-282-8909  
Contact: JOSEPH LANGONE  
Email: jlpowersystems@hotmail.com

Attached is a written quote from our company, which is valid for 30 days.

  
Signature

8/19/13  
Date

Comments: \_\_\_\_\_

NASSAU COUNTY  
FACILITIES MAINTENANCE DEPARTMENT

Office Mailing Address: 45195 Musselwhite Road - Callahan, FL 32011

Nassau County BOCC Mailing Address:  
76347 Veterans Way, Suite 4000 - Yulee, FL 32097  
Email: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)

Telephone: (904) 548-4688  
Alternate: (904) 879-3751  
Fax: (904) 548-4687

**SCOPE of WORK**

(All requests for quotations must be accompanied by this Scope of Work)

**Nassau County Board of County Commissioners**  
**Generator Annual Maintenance and Service Agreement**

Nassau County is requesting quotations for the Annual Maintenance and Service required for each County Owned Generator, as well as any new generators purchased during agreement period. (See attached list indicating the location and Generator information.)

Provide rates for the following: Annual Maintenance and Service as required per Generator:

- 3 Quarterly Minor Services
- 1 Major Service
- 1 Load Bank Test
- List materials with applicable charges for each Generator as listed.

Provide rates for the following services or charges:

- Regular Hourly rate.
- Overtime Hourly rate.
- Any additional mileage charge.
- Truck Charges
- Environmental Charges (that would be applicable for any work, scheduled or unscheduled).
- Any charge not listed please provide detailed information.

\*Please Note:

- Prior to any work, scheduled or unscheduled, proper authorization must be obtained. A PO number will be issued for Annual Maintenance, for any additional repairs a control number must be obtained by contacting the office or through the technician reporting service needs.
- Funding Accounts Numbers have been provided to identify each generator by the department. Please indicate this on all and any invoices to expedite billing processing.
- As generators are being replaced with new units, we will be placing the existing generators at other locations. New units will be under warranty for the first year. (as noted on attached spreadsheet).
- Please provide costs for each Annual Maintenance Service for the following period.
  - Oct1, 2013 - Sept 30, 2014= FY 13/14
  - Oct1, 2014 - Sept 30, 2015= FY 14/15
  - Oct1, 2015 - Sept 30, 2016= FY 15/16

Please respond with pricing to our office by August 14, 2013, should you want to be considered for the Annual Maintenance and Service Agreement, if not please respond with a "No Quote".

All prices must be guaranteed for three (3) years effective October 1, 2013- through September 30, 2016. Any questions you may have please contact Don Castle 904-753-1046, you may also email our Director-Bob Knott at: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)

JL Power

**RATES**

Standard rates for JL Power Systems, Inc.

\$82 per hour standard weekday hours

\$123 per hour, overtime to include Saturdays

\$164 per hour for Sundays and holidays

Billing hours begin from JL Power Systems' driveway

Mileage is \$1.25 per mile

JL Power part 1

These Columns are County Reference.

NASSAU COUNTY GENERATORS

Changes are highlighted in BLUE

JL Power

DEPT.	Nassau County Funding Account (For Budget Purposes).	LOCATION	ADDRESS	PRIMARY USE	Service Requirements.	3 Minor Quarterly PM	2 Hour Load Test	One Major PM	BRAND	KW	VOLTS
NAU	71500536-546000	Nassau Amelia Utilities	5390 First Coast Highway, FB FL 32034	Waste Water Plant	1 Annual Major Service Inspection			Y	CAT	400KVA	480
NAU	71500536-546000	Nassau Amelia Utilities	Omni/Plantation 6027 Villa Partial 3	Repump WTP	1 Annual Major Service Inspection			Y	CAT	565KW	480
NAU	71500536-546000	Nassau Amelia Utilities Plant	5390 First Coast Highway, FB FL 32034	Trailer Mount Generator	1 Annual Major Service Inspection			Y	Armstrong Power	140KVA	230/480
NAU	71500536-546000	Nassau Amelia Utilities Plant	5390 First Coast Highway, FB FL 32034	Water Treatment Plant	1 Annual Major Service Inspection			Y	CAT D343	312 KVA	480
NAU	71500536-546000	Nassau Amelia Utilities - Lift Station 16	6 Amelia Village Circle, FB FL 32034	Lift Station 16	1 Annual Major Service Inspection			Y	ONAN	85 KW	208
JPGC	01188519-546036	James Page Governmental Complex-Onan	96135 Nassau Place, Yulee	COMM. BOARD RM	One major, three minors, full 2 hour load bank test.	Y	Y	Y	ONAN	60	120/240
JPGC	01188519-546036	James Page Governmental Complex-Detroit Diesel	96135 Nassau Place, Yulee	Prop Appr. SOE & Tax Collector	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Detroit Diesel	125	480
Judicial Annex	01189712-534000	Judicial Annex-Courthouse	76435 Veteran's Way, Yulee	JUDICIAL COURTHOUSE	One major, three minors, full 2 hour load bank test.	Y	Y	Y	CUMMINS	300	480
Judicial Annex-Rec.	01189712-534000	Judicial Annex Records Management Building	76435 Veteran's Way, Yulee	RECORDS MAN. BLDG.	One major, three minors, full 2 hour load bank test.	Y	Y	Y	CATERPIL	75	480
Other Co. Bldgs	01193519-546036	Sheriff Admin- 911 Dispatch	50 Bobby Moore Circle, Yulee	911 DISPATCH	One major, three minors, full 2 hour load bank test.	Y	Y	Y	GENERAC	100	480
Other Co. Bldgs	01193519-546036	Repeater Tower - West Side at Landfill	46351 Landfill Rd, Callahan Florida.	REPEATER TOWER WEST SIDE	One major, three minors, full 2 hour load bank test.	Y	Y	Y	GENERAC	15	240
Other Co. Bldgs	01193519-546036	Hilliard Health Clinic (Health Dept Reimburses County)	221 Pecan St., Hilliard, FL 32046	HEALTH DEPT.	One major, three minors	Y	N	Y	KOHLER	15	240
	01072523-546036	Detention Center, Jail	76212 Nicholas Catinha Rd. Yulee	DETENTION CENTER	One major, three minors, full 2 hour load bank test.	Y	Y	Y	TAYLOR	300	
Fire Rescue	01261526-546000	Fire Rescue #30 (Relocating a Tower Site 50 KW to this location Oct 2013)	86026 Pages Dairy Rd., Yulee	FR #30	One major, three minors.	Y	N	Y	GENERAC	50	240
Fire Rescue	01261526-546000	Fire Rescue #40	Pea Farm Rd. Hilliard	FR #40 & WELL	One major, three minors.	Y	N	Y	GENERAC	50	240
Fire Rescue	01261526-546000	Vol Station #7-	1426 Nassauville Rd., Fernandina Beh.	MOBILE	1 Annual Major Service Inspection	N	N	Y	KUBOTA	6	240
Fire Rescue	01261526-546000	Vol Station #3	Goodbread Drive Yulee, FL 32097	MOBILE UNIT	1 Annual Major Service Inspection	N	N	Y	KUBOTA	6	240
Fire Rescue	01261526-546000	Fire Rescue #70 (Relocating a Tower Site 50 KW to this location Oct 2013)	4061 Pine Grove Rd.(O'Neil), FB, FL 32034		One major, three minors, full 2 hour load bank test.	Y	N	Y	Generac	50	240
Fire Rescue	01261526-546000	Fire Rescue Head Quarters & Fire Rescue 20 (NEW)	96160 Nassau Place, Yulee, FL 32097	Trailer Mount-	One major, three minors, full 2 hour load bank test.	Y	N	Y	Tradewind	56	240
BOCC Radio	1252525-546000-MCOMM	Hilliard Tower Site (Current units will be placed through the Co.)	371105 Oxford St, Hilliard	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	35	240
BOCC Radio	1252525-546000-MCOMM	Callahan Tower Site (Current units will be placed through the Co.)	46351 Landfill Rd	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	50	240
BOCC Radio	1252525-546000-MCOMM	Bryceville Tower Site (Current units will be placed through the Co.)	11701 Old North Trail	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	35	240
BOCC Radio	1252525-546000-MCOMM	Yulee Tower Site (Current units will be placed through the Co.)	462684 SR 200	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	50	240
BOCC Radio	1252525-546000-MCOMM	Fernandina Beach Tower Site (Current units will be placed through the Co.)	1559 S 14th St	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	25	240
BOCC Radio	1252525-546000-MCOMM	Yulee Master Site (Current units will be placed through the Co.)	76001 Bobby Moore Circle	Radio System	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Generac	50	240
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	35	240
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	50	240
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	35	240
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	50	240
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	25	240
BOCC Radio	1252525-546000-MCOMM	New Generators will be purchased 13/14 for the Tower Sites			One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	50	240
BOCC Radio	1252525-546000-MCOMM	New Trailer Mount Generators will be purchased 13/14		Trailer Mount	One major, three minors, full 2 hour load bank test.	Y	Y	Y	Tradewind	50	240
Solid Waste	70362534-546000	Landfill East Side Pumping Station	46026 Landfill Road, Callahan 32011	Pumping stations	One major, three minors	Y	N	Y	Caterpillar	23.3	240
Solid Waste	70362534-546000	Landfill West Side Pumping Station	46026 Landfill Road, Callahan 32011	Pumping stations	One major, three minors	Y	N	Y	Hollingsworth	30	240
Solid Waste	70362534-546000	Landfill Leachate Pumping Station	46026 Landfill Road, Callahan 32011	Leachate Tanks Pumping	One major, three minors	Y	N	Y	Onan	40	240
Solid Waste	70362534-546000	Landfill Flare System (New Unit installed on 4/29/13)	46026 Landfill Road, Callahan 32011	Flare System	One major, three minors	Y	N	Y	Tradewind	125	480
Solid Waste	70369534-546000	Landfill Convenience Center	46026 Landfill Road, Callahan 32011	Convenience Center	One major, three minors	Y	N	Y	Caterpillar	60	120/240
Animal Control	01193519-546036	Animal Control and Care Service	86078 License Road Yulee 32097	Building and Kennels	One major, three minors	Y	N	Y	Maspower	35.2	120/240
Emergency Services	01253525-546036	Emergency Operations Center	77150 Citizen's Circle Yulee 32097	Building	One major, three minors, full 2 hour load bank test.	Y	Y	Y	GENERAC	150	120/208
Hilliard R&B	03404541-546000	Hilliard Road & Bridge-Office	37356 Pea Farm Rd. Hilliard, FL.	Hilliard Yard Main Office	1 Annual Major Service Inspection	N	N	Y	GENERAC	30	240
Bailey Road	03404541-546000	Hilliard Road & Bridge - Shop	37356 Pea Farm Rd. Hilliard, FL.	Hilliard Yard Maintenance Shop	1 Annual Major Service Inspection	N	N	Y	GENERAC	30	240
Road and Bridge	03404541-546000	Bailey Road & Bridge	3163 Bailey Rd. Fernandina Beh. FL.	Bailey Yard	1 Annual Major Service Inspection	N	N	Y	GENERAC	20	240





Nassau County Board of County Commissioners  
Request for Quotation Form

Requesting Department: Facilities Maintenance Date: 8/2/13

Department Address: 45195 Musselwhite Road, Callahan, FL 32011

Contact: Don Castile (Maintenance Tech.) 904-753-1046  
or Bob Knott (Director) 904-548-4688

Contact email: Bob Knott- Director: bknott@nassaucountyfl.com

Department Phone: (904) 548-4688 or (904) 548-4689

Department Fax: (904) 548-4687

Product(s)/Service(s) to be purchased (list all specifications and requirements):

See attached Scope of Work for Nassau County Board of County Commissioners-Generator Annual Maintenance and Service Agreement (See attached documents).

**Please note:**

**This document must be completed and sent back with the attached Scope of Work with your quotation.**

➤ If additional/alternate scope of service or product is recommended, please provide as a separate attachment: Additional Attachment Yes  No

\*All payments for products /services are as per Florida Statutes 218.73 & 218.74 (Terms net 45 days). \*

Please submit written response by: August 14, 2013 *extended due to death in family 8/16*  
(Date)

Faxed / Scanned/Emailed to Vendor on 8/2/13 to the attention of Jimmy Jacobs

To be completed by vendor:

Vendor Name: Florida Detroit Diesel- Allison, Inc.

Address: PO Box 16595  
Jacksonville, Florida 32245

Phone: 407-948-7402 Fax: 1-866-902-4064

Contact: Jimmy Jacobs

Email: jjacobs@fdeda.com

Attached is a written quote from our company, which is valid for 90 days.

Jimmy Jacobs  
Signature

8/27/2013  
Date

Comments: \_\_\_\_\_

NASSAU COUNTY  
FACILITIES MAINTENANCE DEPARTMENT

Office Mailing Address: 45195 Musselwhite Road - Callahan, FL 32011

Nassau County BOCC Mailing Address:  
76347 Veterans Way, Suite 4000 - Yulee, FL 32097  
Email: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)

Telephone: (904) 548-4688  
Alternate: (904) 879-3751  
Fax: (904) 548-4687

**SCOPE of WORK**

(All requests for quotations must be accompanied by this Scope of Work)

**Nassau County Board of County Commissioners**  
**Generator Annual Maintenance and Service Agreement**

Nassau County is requesting quotations for the Annual Maintenance and Service required for each County Owned Generator, as well as any new generators purchased during agreement period. (See attached list indicating the location and Generator information.)

Provide rates for the following: Annual Maintenance and Service as required per Generator:

- 3 Quarterly Minor Services
- 1 Major Service
- 1 Load Bank Test
- List materials with applicable charges for each Generator as listed.

Provide rates for the following services or charges:

- Regular Hourly rate.
- Overtime Hourly rate.
- Any additional mileage charge.
- Truck Charges
- Environmental Charges (that would be applicable for any work, scheduled or unscheduled).
- Any charge not listed please provide detailed information.

\*Please Note:

- Prior to any work, scheduled or unscheduled, proper authorization must be obtained. A PO number will be issued for Annual Maintenance, for any additional repairs a control number must be obtained by contacting the office or through the technician reporting service needs.
- Funding Accounts Numbers have been provided to identify each generator by the department. Please indicate this on all and any invoices to expedite billing processing.
- As generators are being replaced with new units, we will be placing the existing generators at other locations. New units will be under warrantee for the first year. (as noted on attached spreadsheet).
- Please provide costs for each Annual Maintenance Service for the following period.
  - Oct1, 2013 - Sept 30, 2014= FY 13/14
  - Oct1, 2014 - Sept 30, 2015= FY 14/15
  - Oct1, 2015 - Sept 30, 2016= FY 15/16

Please respond with pricing to our office by August 14, 2013, should you want to be considered for the Annual Maintenance and Service Agreement, if not please respond with a "No Quote".

All prices must be guaranteed for three (3) years effective October 1, 2013- through September 30, 2016. Any questions you may have please contact Don Castle 904-753-1046, you may also email our Director-Bob Knott at: [bknott@nassaucountyfl.com](mailto:bknott@nassaucountyfl.com)



**Suzie Fontes**

---

**From:** Mark McGauley <mmcgauley@fdda.com>  
**Sent:** Sunday, August 11, 2013 10:17 PM  
**Subject:** Read: Nassau County Generator- Request for Quote

Your message

To: [mmcgauley@fdda.com](mailto:mmcgauley@fdda.com)  
Subject:

was read on 8/11/2013 10:17 PM.

**Suzie Fontes**

---

**From:** Mark McGauley <mmcgauley@fdda.com>  
**Sent:** Friday, August 02, 2013 1:24 PM  
**Subject:** Read: Nassau County Generator- Request for Quote

Your message

To: [mmcgauley@fdda.com](mailto:mmcgauley@fdda.com)  
Subject:

was read on 8/2/2013 1:24 PM.

**Suzie Fontes**

---

**From:** postmaster@nassaucountyfl.com  
**Sent:** Friday, August 02, 2013 10:25 AM  
**To:** Suzie Fontes  
**Subject:** Delivery Status Notification (Relay)  
**Attachments:** ATT150138.txt; FW: Nassau County Generator- Request for Quote

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

[mmcgauley@fdda.com](mailto:mmcgauley@fdda.com)

FDDA

NASSAU COUNTY GENERATOR SERVICE  
2013 REQUEST FOR PROPOSAL PREPARED BY FLORIDA DETROIT DIESEL-ALLISON, INC.

LOCATION	MAKE	KW	QUART. INSPCT COST (minor)	# OF INSP'S	TOTAL COST OF QUARTERLY INSPECTION	ANNUAL PM (major)	2-HR LOAD BANK TEST COST	2014 Total Cost	2015 Total Cost	2016 Total Cost
<b>Nassau Utilities</b>										
5390 First Coast	CAT	350	\$135.00	3	\$405.00	\$695.00		\$1,100.00	\$1,133.00	\$1,166.99
6027 Villa Partial			\$135.00	3	\$405.00	\$785.00		\$1,190.00	\$1,225.70	\$1,262.47
5390 First Coast - Trailer	Trailer	115	\$135.00	3	\$405.00	\$589.00		\$994.00	\$1,023.82	\$1,054.53
5390 First Coast WWTP		250	\$135.00	3	\$405.00	\$589.00		\$994.00	\$1,023.82	\$1,054.53
Lift Station 16		85	\$135.00	3	\$405.00	\$495.00		\$900.00	\$927.00	\$954.81
Repeater Tower - West Side Landfill		15	\$115.00	3	\$345.00	\$325.00	\$500.00	\$1,170.00	\$1,205.10	\$1,241.25
Fire & Rescue Station 20 Trailer/Tradewinds		56	\$115.00	3	\$345.00	\$495.00	\$500.00	\$1,340.00	\$1,380.20	\$1,421.61
Tower Site 1		25	\$115.00	3	\$345.00	\$350.00	\$500.00	\$1,195.00	\$1,230.85	\$1,267.78
Tower Site 2		35	\$115.00	3	\$345.00	\$355.00	\$500.00	\$1,200.00	\$1,236.00	\$1,273.08
Tower Site 3		35	\$115.00	3	\$345.00	\$355.00	\$500.00	\$1,200.00	\$1,236.00	\$1,273.08
Tower Site 4		50	\$115.00	3	\$345.00	\$495.00	\$500.00	\$1,340.00	\$1,380.20	\$1,421.61
Tower Site 5		50	\$115.00	3	\$345.00	\$495.00	\$500.00	\$1,340.00	\$1,380.20	\$1,421.61
Tower Site 6		50	\$115.00	3	\$345.00	\$495.00	\$500.00	\$1,340.00	\$1,380.20	\$1,421.61
Tower Site 7		50	\$115.00	3	\$345.00	\$495.00	\$500.00	\$1,340.00	\$1,380.20	\$1,421.61
EMERGENCY SERVICES	GENERAC	150	\$135.00	3	\$405.00	\$595.00	\$530.00	\$1,530.00	\$1,575.00	\$1,623.17
JUDICIAL COMPLEX	CUMMINS	300	\$135.00	3	\$405.00	\$645.00	\$720.00	\$1,770.00	\$1,823.10	\$1,877.79
RECORDS MANAGEMNT BLDG	CAT	75	\$135.00	3	\$405.00	\$529.00	\$545.00	\$1,479.00	\$1,523.37	\$1,569.07
SHERIFF ADMIN - 911 DISPATCH	GENERAC	100	\$135.00	3	\$405.00	\$486.00	\$520.00	\$1,411.00	\$1,453.33	\$1,496.92
LANDFILL REPEATER TOWER	GENERAC	15	\$125.00	3	\$375.00	\$345.00	\$450.00	\$1,170.00	\$1,205.10	\$1,241.25
DETENTION CENTER, (NEW JAIL)	(VOLVO PENTA)	300	\$135.00	3	\$405.00	\$595.00	\$720.00	\$1,720.00	\$1,771.60	\$1,824.74
FIRE RESCUE #30	GENERAC	15	\$125.00	3	\$375.00	\$343.00	\$0.00	\$718.00	\$739.54	\$761.62
FIRE RESCUE #40	GENERAC	50	\$125.00	3	\$375.00	\$438.00	\$0.00	\$813.00	\$837.39	\$862.51
FIRE RESCUE #20	Tradewinds	56	\$125.00	3	\$375.00	\$495.00	\$0.00	\$870.00	\$896.10	\$922.98
FIRE RESCUE #60	GENERAC	15	\$0.00	0	\$0.00	\$0.00	\$0.00	n/a	n/a	
FIRE RESCUE #70	KUBOTA	6	\$0.00	0	\$0.00	\$258.00	\$0.00	\$258.00	\$265.75	\$275.00
VOLUNTEER STATION #7	KUBOTA	6	\$0.00	0	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00
BAILEY ROAD & BRIDGE	GENERAC	20	\$0.00	0	\$0.00	\$337.00	\$0.00	\$337.00	\$347.11	\$357.52
HILLIARD CNTY BLDG.	KOHLER	15	\$125.00	3	\$375.00	\$357.00	\$0.00	\$732.00	\$753.96	\$776.57
HILLIARD R & B OFFICE	GENERAC	30	\$0.00	0	\$0.00	\$325.00	\$0.00	\$325.00	\$334.75	\$344.79
HILLIARD R & B SHOP	GENERAC	30	\$0.00	0	\$0.00	\$325.00	\$0.00	\$325.00	\$334.75	\$344.79
VOLUNTEER STATION #3	KUBOTA	6	\$0.00	0	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00
HILLIARD TOWER SITE	GENERAC	35	\$135.00	3	\$405.00	\$454.00	\$505.00	\$1,364.00	\$1,404.92	\$1,447.06
CALLAHAN TOWER SITE	GENERAC	50	\$135.00	3	\$405.00	\$454.00	\$520.00	\$1,379.00	\$1,421.29	\$1,463.92
BRYCEVILLE TOWER SITE	GENERAC	35	\$135.00	3	\$405.00	\$454.00	\$505.00	\$1,364.00	\$1,404.92	\$1,447.06
YULEE TOWER SITE	GENERAC	50	\$135.00	3	\$405.00	\$454.00	\$520.00	\$1,379.00	\$1,421.29	\$1,447.06
FERN. BEACH TOWER SITE	GENERAC	25	\$135.00	3	\$405.00	\$443.00	\$485.00	\$1,333.00	\$1,372.99	\$1,414.17
YULEE MASTER SITE	GENERAC	50	\$135.00	3	\$405.00	\$454.00	\$520.00	\$1,379.00	\$1,421.29	\$1,447.06
N.C.Governmental Complex	MTU	125	\$135.00	3	\$405.00	\$520.00	\$520.00	\$1,615.00	\$1,663.45	\$1,713.35
Landfill East Pump Station	Military	30	\$125.00	3	\$375.00	\$416.00	na	\$791.00	\$814.73	\$839.17
Landfill West Pump Station	Military	30	\$125.00	3	\$375.00	\$416.00	na	\$791.00	\$814.73	\$839.17
Landfill Leachate Station	Onan	40	\$125.00	3	\$375.00	\$423.00	na	\$798.00	\$821.94	\$846.59
Landfill Flare Station	Kohler	125	\$125.00	3	\$375.00	\$438.00	na	\$813.00	\$837.39	\$862.51
Landfill Conv. Center	Cat	60	\$125.00	3	\$375.00	\$465.00	na	\$840.00	\$865.20	\$891.15
Animal Services	Manpower	35	\$125.00	3	\$375.00	\$454.00	na	\$829.00	\$853.87	\$879.48
Emergency Operation Center	Generac	150	\$135.00	3	\$405.00	\$520.00	\$520.00	\$1,445.00	\$1,488.35	\$1,533.00
								\$46,221.00	\$47,609.50	\$49,060.03

<b>Hourly Rates For Additional Services</b>	
MONDAY - FRIDAY 7:30AM - 4:00PM	\$80.00 PER HOUR - PORT TO PORT
MONDAY - FRIDAY 4:00PM - 7:30AM	\$120.00 PER HOUR - PORT TO PORT
SATURDAY - ALL DAY	\$120.00 PER HOUR - PORT TO PORT
SUNDAY - ALL DAY	\$160.00 PER HOUR - PORT TO PORT
HOLIDAYS - ALL DAY	\$225.00 PER HOUR - PORT TO PORT
THERE IS A 7.5% CHARGE ON ALL LABOR.	
MILEAGE CHARGE - \$50.00 Per Trip OTHER THAN SCHEDULED MAINTENANCE.	



B&K Diesel Engines

**Suzie Fontes**

---

**From:** Dianne Sowell <gensets@bellsouth.net>  
**Sent:** Wednesday, August 14, 2013 1:58 PM  
**To:** Suzie Fontes  
**Subject:** RE: Nassau County Generator- Request for Quote

Suzie Fontes,  
We will have to take a "No Bid" at this time.

Thank you for the consideration.

Bill Crumbley  
B&K Diesel Electric Service, Inc.

---

**From:** Suzie Fontes [mailto:sfontes@nassaucountyfl.com]  
**Sent:** Friday, August 9, 2013 3:43 PM  
**To:** gensets@bellsouth.net  
**Subject:** FW: Nassau County Generator- Request for Quote

Please see the attached Amendment #1 to the Generator Spreadsheet sent out on August 2, 2013. I also attached the Original Request - Scope of Work. We are extending the due date to August 19, 2013 due to the revisions.

Thank you,

---

**From:** Suzie Fontes  
**Sent:** Friday, August 02, 2013 10:07 AM  
**To:** 'gensets@bellsouth.net'  
**Subject:** Nassau County Generator- Request for Quote

Emailed on Behalf of Don Castle:

Please see all attachments.

Suzie Fontes - Office Manager  
Nassau County Facilities Maintenance/Parks & Recreation Dept.  
45195 Musselwhite Road, Callahan, FL 32011  
Office 904-548-4688 ext 6303 Fax: 904-548-4687

**Suzie Fontes**

---

**From:** Dianne Sowell <gensets@bellsouth.net>  
**Sent:** Tuesday, August 13, 2013 8:19 AM  
**To:** Suzie Fontes  
**Subject:** Read: Nassau County Generator- Request for Quote  
**Attachments:** ATT235227.txt

Your message

To: [gensets@bellsouth.net](mailto:gensets@bellsouth.net)  
Subject: FW: Nassau County Generator- Request for Quote  
Sent: 8/9/2013 3:43 PM

was read on 8/13/2013 8:18 AM.

**Suzie Fontes**

---

**From:** postmaster@nassaucountyfl.com  
**Sent:** Friday, August 09, 2013 3:48 PM  
**To:** Suzie Fontes  
**Subject:** Delivery Status Notification (Relay)  
**Attachments:** ATT220611.txt; FW: Nassau County Generator- Request for Quote

This is an automatically generated Delivery Status Notification.

Your message has been successfully relayed to the following recipients, but the requested delivery status notifications may not be generated by the destination.

[gensets@bellsouth.net](mailto:gensets@bellsouth.net)



Nassau County Board of County Commissioners  
Request for Quotation Form

Requesting Department: Facilities Maintenance Date: 8/2/13

Department Address: 45195 Musselwhite Road, Callahan, FL 32011

Contact: Don Castle ( Maintenance Tech.) 904-753-1046  
or Bob Knott (Director) 904-548-4688

Contact email: Bob Knott- Director: bknott@nassaucountyfl.com

Department Phone: (904) 548-4688 or (904) 548-4689

Department Fax: (904) 548-4687

Product(s)/Service(s) to be purchased (list all specifications and requirements):

See attached Scope of Work for Nassau County Board of County Commissioners-Generator Annual Maintenance and Service Agreement (See attached documents).

**Please note:**

**This document must be completed and sent back with the attached Scope of Work with your quotation.**

➤ If additional/alternate scope of service or product is recommended, please provide as a separate attachment: Additional Attachment Yes  No

\*All payments for products /services are as per Florida Statutes 218.73 & 218.74 (Terms net 45 days). \*

Please submit written response by: August 14, 2013  
(Date)

Faxed / Scanned/Emailed to Vendor on 8/2/13 to the attention of B&K Diesel

To be completed by vendor:

Vendor Name: B & K Diesel

Address: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

Contact: \_\_\_\_\_

Email: \_\_\_\_\_

Attached is a written quote from our company, which is valid for \_\_\_\_\_ days.

\_\_\_\_\_  
Signature Date

Comments: \_\_\_\_\_