

ORDINANCE 94 - 21

AN ORDINANCE AMENDING ORDINANCE 87-18, AS AMENDED, WHICH ESTABLISHED SUBDIVISION REGULATIONS FOR THE UNINCORPORATED AREAS OF NASSAU COUNTY; SPECIFICALLY AMENDING SECTION VI, WATER LINES, ADDING PARAGRAPH D; PROVIDING AN EFFECTIVE DATE.

WHEREAS, the Fire Safety Inspector has made the Board of County Commissioners aware of the Nationally Recognized Standards regarding fire hydrants; and

WHEREAS, the Board finds that it is in the best interest of the citizens of Nassau County to adopt said standards.

NOW, THEREFORE, BE IT ORDAINED this 14th day of March, 1994, by the Board of County Commissioners of Nassau County, Florida, that Ordinance 87-18, as amended, be further amended as follows:


SECTION VI: WATER LINES

1. Where an approved public water supply is reasonably accessible, each lot within the subdivision shall be provided with a connection to such water supply. The water service for each lot will be installed at the time of the application for a building permit. All mains, to be under paving, will be constructed prior to the paving installation. Fire hydrants will be installed in all subdivisions where a public water supply is available or will be constructed as in (2) below. The spacing of fire hydrants shall be a maximum of 500 feet, measured along the roadway. Placement of fire hydrants shall occur at street intersections where possible. All fire hydrants shall be connected to water mains of six (6)

minimum size. New fire hydrant(s) shall be installed so that four and one-half inch (4-1/2") port is facing the roadway by which it is accessed. Hydrant(s) shall be positioned not more than five feet (5') away from the curb or berm of the roadway. All fire hydrants shall be painted chrome yellow. Where no commercial or residential development has occurred, fire hydrant placement can be delayed until such development dictates its installation. The location of fire hydrants shall be approved by the Public Safety Director or his designee.

4. This Ordinance shall become effective upon its being filed in the office of the Secretary of State.

BOARD OF COUNTY COMMISSIONERS
NASSAU COUNTY, FLORIDA



JOHN A. CRAWFORD
Its: Chairman

ATTEST:



T. J. GREASON
Its: Ex-Officio Clerk

7
Approved as to form by the Nassau
County Attorney



MICHAEL S. MULLIN

6/b:\hydrant.ord